



**Mandatory testing shall be carried out in accordance with AS/NZS 3000.**

AS/NZS 3017 sets out some of the common test methods required to test that a low voltage electrical installation complies with AS/NZS 3000.

Date (DD/MM/YY)			OTR Reference No			ECC No		
Address/location								
Registered Electrical Worker's Name			Signature			Registration No PGE		
Switchboard / Distribution board No			PSC <sup>b</sup> at Main Switch			KA	Incoming current (if supply available)	
All live parts screened from touch without use of tool?	Yes	No					RØ: A	WØ: A BØ: A

**Test equipment**

Type / Model #	Serial #	Calibration date	Type / Model #	Serial #	Calibration date
Type / Model #	Serial #	Calibration date	Type / Model #	Serial #	Calibration date

**Main switchboard, consumers mains & main earth**

M.E.N Connection & Main switchboard earthing compliant	Main Switch / Load Limiter			Conductor		Earth Continuity (ohms)		Insulation Resistance (Megohms)		Polarity	CCT CXN <sup>e</sup>	Comments	
	Type <sup>a</sup>	Current rating (A)	PSC rating <sup>b</sup> (kA)	C.C.C <sup>c</sup> (A)	Size (mm <sup>2</sup> )	Main earth	EQ bonding conductors <sup>d</sup>	A - E <sup>d</sup>	A - N <sup>d</sup>	N - E	Phase - Phase <sup>d</sup>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	
Yes	No					Ω	Ω					<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	

**Submains**

Circuit ID & No of phases	Over Current Protective Device			Conductor		Earth Continuity (ohms)		Insulation Resistance (Megohms)		Polarity	CCT CXN <sup>e</sup>	Earth fault loop impedance	RCD test results				
	Type <sup>a</sup>	Current rating (A)	PSC rating <sup>b</sup> (kA)	C.C.C <sup>c</sup> (A)	Size (mm <sup>2</sup> )	Submain earths	EQ bonding conductors <sup>d</sup>	A - E <sup>d</sup>	A - N <sup>d</sup>	N - E	Phase - Phase <sup>d</sup>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	Push button test	Isolation of live poles	Supply not available - testing pending <sup>f</sup>	No RCD
						Ω	Ω					<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	Ω			
						Ω	Ω					<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	Ω			
						Ω	Ω					<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	Ω			
						Ω	Ω					<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	Ω			
						Ω	Ω					<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> / <input checked="" type="checkbox"/>	Ω			

**Comments**

--

a. Protective device types: Rewireable fuse = **rf**, HRC fuse = **hrc**, Circuit breaker = **c/b** **B** **C** or **D**, MCB/RCD combo = **rcd**, Isolator = **isol**.  
 b. PSC = Prospective Short-circuit Current in kA. Ref AS/NZS 3000.  
 c. C.C.C = Current Carrying Capacity of the conductor after derating in A. Ref AS/NZS 3008.

d. Where multiple results are obtained due to multiphase, multiple EQ bonds etc, record the lowest insulation resistance & highest earth resistance readings obtained.  
 e. CCT CXN = Correct circuit connection  
 f. I will return to site to energise and test RCD after supply is available.

