

Install Insulation in an Uninsulated Ceiling Space; (Residential and Small Energy Consuming Customers Only)	Activity No.
	BS1A

1. ACTIVITY SPECIFIC DEFINITIONS

Habitable Room means any space that can be occupied within a building. This does not include any attached garages, sheds or the like in class 1 or 2 buildings or storage spaces or similar within commercial buildings that are not space conditioned.

Ceiling means the uppermost surface of a habitable room that has an exposed roof or the attic space of an exposed roof immediately above. Ceilings do not include ceilings of rooms that have another habitable room above the subject portion of the ceiling.

Uninsulated ceiling space means a ceiling space without ceiling insulation installed. For the purposes of this activity, ceiling spaces with single sheet reflective foil insulation hung below the roofing material are deemed to be uninsulated ceiling spaces.

Insulation Area means the area of ceiling space where insulation is to be installed by this activity. It is expressed as square metres (metres × metres).

2. ACTIVITY DESCRIPTION (SUMMARY)

Install insulation in an uninsulated ceiling space above a habitable room

3. ACTIVITY ELIGIBILITY REQUIREMENTS

- (1) A residential or small energy consuming customers premises subject to this activity must contain at least 20m² of uninsulated ceiling space above a habitable room or rooms that are practical to insulate.
- (2) All habitable rooms with uninsulated ceiling spaces that are practical to insulate must be insulated as part of this activity.
- (3) The installation of ceiling insulation must not be otherwise required by law, for example as condition of a development approval under the *Development Act 1993* or the *Planning, Development and Infrastructure Act 2016*.
- (4) A valid tax invoice must be retained for verification purposes, clearly showing the completion date, the address that the insulation was installed in, the name and contact details of the person billed for the installation, and the amount charged for the installation.
- (5) The following activities are excluded:
 - Use of reflective foil laminate sheeting
 - Use of blow in cellulous-based products

4. INSTALLED PRODUCT REQUIREMENTS

The installed product must:

- (1) Comply with the performance requirements of the effective version of AS/NZS 4859.1:2018
- (2) Achieve a minimum winter R value, when measured in accordance with the effective version of AS/NZS 4859.1:2018 of:
 - R3.5 if the Site is in NCC Climate Zone 4 or 5
 - R5.0 if the Site is in NCC climate zone 6

- (3) Comply with any product safety or other product performance requirements in a relevant code of practice or other relevant legislation applying to the activity
- (4) Be fit for the purpose for which it is intended to be used
- (5) Come with a minimum 5-year product warranty.

5. MINIMUM INSTALLATION REQUIREMENTS

- (1) The insulation product used must be installed in compliance with the effective version of AS 3999, AS/NZS 3000 (as applicable) and the NCC Section J1.2. In particular, the safety, pre-inspection and risk assessment procedures, electrical safety provisions and provisions for limiting moisture ingress of AS 3999 shall be observed.
- (2) The activity must be completed and certified in accordance with any relevant code or codes of practice and other relevant legislation applying to the activity, including any licensing, registration, statutory approval, activity certification, health, safety, environmental or waste disposal requirements.
- (3) The undertaking of this activity shall not compromise the condensation management of the building. Reference should be made to the provisions in the Australian Building Codes Board publication “Condensation in buildings – Information handbook”.
- (4) Cut outs around ceiling penetrations such as down-lights must be kept to the minimum permitted by AS 3999.
- (5) The installing business must complete and provide to the recipient of the activity a signed copy of the “Installer Acknowledgement Form” section of the SA Government’s “Installation of Ceiling Insulation – Consumer Safety Self- Assessment and Installer Acknowledgement Form”, available from <https://www.sa.gov.au>. A copy of this completed and signed form must also be retained for verification purposes.
- (6) Photographs of the activity in its location (date and location stamped), before and after the upgrades that coincide with the location are required for record keeping and verification.
- (7) The business or person undertaking the activity must have a building work contractor license which includes insulation within its scope of activities under the *Building Work Contractors Act 1995*.
- (8) The activity must be overseen by a supervisor who is registered to undertake ceiling insulation work with Consumer and Business Services.
- (9) Any person installing insulation as part of this activity must hold a construction industry ‘White Card’.

6. NORMALISED REPS GIGAJOULES

The normalised REPS gigajoules achieved from undertaking this activity is equal to:

Normalised REPS GJs = Productivity Factor (as per table below) x Insulation Area (m^{2*}) x REPS Transition Factor (as per table below)

ACTIVITY BS1A - PRODUCTIVITY FACTORS

Activity	Productivity Factor
NCC Zones 4&5 – install R3.5 insulation	1.389
NCC Zones 6 – Install R5.0 insulation	1.689

* Where cut-outs are made (e.g. around down-lights) an area equal to the actual cut-out shall be excluded from the calculation of the REPS gigajoules.