

Our Ref: REB 130.13



1 November 2013

Mr Mark Howe
Mining Assessments
Department of Manufacturing, Innovation, Trade, Resources and Energy
Mineral Resources Division
Level 3
101 Grenfell Street
ADELAIDE SA 5000

Dear Mr Howe

RE: Applications for Mineral Lease, Extractive Minerals Lease and Miscellaneous Purposes Licence

Thank you for providing the opportunity for SA Power Networks to comment on the above project.

SA Power Networks could have substantial electricity infrastructure within the allotted area such as overhead lines, underground cables and poles.

SPECIFIC COMMENTS

3.3.4.2 Electricity Supply

SA Power Networks Ardrossan West, Hummocks and Kadina East connection points have been upgraded to meet the revised 2008 Electricity Transmission code since the details in this report we obtained.

SA Power Networks distribution infrastructure servicing the Yorke Peninsula area is regularly maintained and augmented as required, to ensure that it has sufficient capacity to supply normal residential, rural and commercial loads located in the area.

T2951-V02
A1799746

6.5 Hillside Project Dust and Odour Impact

If there were significant releases of dust from the mine site, this may impact on our 33kV and 19kV SWER lines in the area. If this was significant, it may require an increase in dust pollution inspection and washing, especially over the dryer months.

SA Power Networks would expect that the Department of Manufacturing, Innovation, Trade, Resources and Energy will ensure that dust emissions from the proposed mine will be within required limits. This will limit the impact on the reliability of our distribution system and any detrimental effect on our customers.

If this project proceeds as proposed, the rate of load growth and general customer work will increase significantly in the local area. This will be driven by domestic and commercial load increases and residential development.

SA Power Networks should be consulted on any modifications to any of our sites located within the allotted area as 24/7 access must be maintained to the property. This would include, but not be limited to changes to;


- access conditions;
- landscaping
- stormwater disposal;
- road, crossovers and footpath construction.

Matters relating to building near power lines and other infrastructure and/or the use of heavy plant and equipment (including backhoes and cranes), fall under the control of the Office of the Technical Regulator and we would strongly advise you to discuss the proposal with that Office (telephone no.8226 5500) before committing to any physical works.

It is also recommended that the Developer undertake a Dial Before You Dig inquiry to ensure there are no underground electricity or other utility cables, pipes or services in the area. Your inquiry may be lodged online <http://www.1100.com.au/> or by calling telephone no. 1100.

Should the proposed development necessitate an upgrade of power supply in the area or an upgrade or modification of electricity infrastructure the prospective developer should contact SA Power Networks' Builders and Contractors' line in this regard on telephone no. 1300 650 014.

Yours sincerely



Jane Jusup
Real Estate Support Officer

