

Our Ref: F2023/001079



**Government  
of South Australia**

**Department for  
Energy and Mining**



Via email: [REDACTED]

Dear [REDACTED]

I am writing in relation to your application made under the *Freedom of Information Act 1991* (FOI Act) in which you requested access to the following document:

*The ECOC for the solar installation at [REDACTED] for [REDACTED].*

In accordance with Premier and Cabinet Circular PC045, if you are given access to documents as a result of this FOI application, details of your application, and the documents to which access is given, may be published in the agency's disclosure log. A copy of PC045 can be found at <http://dpc.sa.gov.au/what-we-do/services-for-government/premier-and-cabinet-circulars>.

A search has been conducted and one (1) document was discovered that falls within the scope of your application. The document is identified in the attached schedule. In respect of the document, I have determined as follows:

### **Document 1**

I have determined that this document should be released in full.

### **Appeal Rights**

If you are dissatisfied with this decision, you are entitled to exercise your rights of review and appeal as outlined in the attached documentation.

If you have any queries in relation to your application, please contact me via email [DEM.FOI@sa.gov.au](mailto:DEM.FOI@sa.gov.au).

Yours sincerely

A handwritten signature in blue ink, appearing to read "R J Faunt".

**Rob Faunt  
Accredited FOI Officer**

6 June 2023

#### **CORPORATE SERVICES**

Level 4, 11 Waymouth Street, Adelaide SA 5000 | GPO Box 320 Adelaide SA 5001 | DX452  
Tel (+61) 8463 3000 | ABN 83 768 683 934



## SCHEDULE OF DOCUMENTS

Freedom of Information application by [REDACTED], seeking access to:

*The ECOC for the solar installation at [REDACTED] for [REDACTED]*

Doc No	Description	Exemption Clause(s)	Determination
1	Electrical certificate of compliance number E1589586		Document released in full.

# ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the Electricity Act 1996

Certificate Number: **E1589586**

Owner/Client name	[REDACTED]		
Installation Address	[REDACTED]		
Premises Type	House/Domestic		
Date of Electrical Work	Started: 21/09/2022	Finished: 21/09/2022	Submitted: 23/09/2022
Network Operator	SAPN		

## SECTION A - JOB DETAILS

Job Category	Job Type	Work Performed
New Install	Inverter/Battery/ Solar/Generator	<b>Grid Connected</b> Relevant Agent: SA Power Networks - Growatt <b>Solar</b> Solar Manufacturer: Chint Solar Zhejiang Co Ltd Module Model: CHSM60M-HC-370 Solar Number of Modules: 14 Solar Total Capacity: 5.18 (kW) <b>Inverter</b> Inverter Manufacturer: Shenzhen Growatt New Energy Co Ltd Inverter Model: MIN 5000TL-X (AS4777-2 2020) Inverter Grid Code Settings: AS/NZS 4777.2:2020 (Australia A)  Electrical Work Details: Install 5.18 kw solar system 2 string of 6 and 8 on house north roof 25 amp ac breaker 63A meter isolator

**SECTION B - WARNING :** Owners & operators of electrical installations must take reasonable steps to ensure that the electrical installation is safe. Maximum penalty \$250,000. Listed below are any items considered to be unsafe or requiring remedy.

Risk Assessment	None Observed
-----------------	---------------

**REGISTERED ELECTRICAL WORKER:** I certify the work detailed in this eCoC complies with and has been inspected and tested by me as required by the *Electricity Act 1996*.

Name	[REDACTED]
Licence Number	[REDACTED]
Date Certified	23/09/2022

# ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the Electricity Act 1996

Certificate Number: **E1589586**

<b>CONTRACTOR/AUTHORISED PERSON:</b> I certify that I am the contractor/duly authorised agent of the contractor and have or had a supervisory role in relation to the worker above and I am satisfied that the standards and requirements of the <i>Electricity Act 1996</i> have been complied with. Also where applicable, I am satisfied that the auxiliary gas fitting and/or water plumbing work detailed above meets the requirements of the <i>Gas Act 1997</i> and Regulations and/or <i>Water Industry Act 2012</i> including Regulations and Standards.			
Name	[REDACTED]		
Business Name	[REDACTED]		
Licence Number	[REDACTED]		
Phone/Mobile	[REDACTED]	Email	[REDACTED]
Address	[REDACTED]		
Date Certified	23/09/2022		

The Technical Regulator does not endorse the contents of this electronic Certificate of Compliance (eCoC). The Technical Regulator does not accept responsibility for the truth or accuracy of the contents of this eCoC and will not be held liable for any loss or damage suffered in consequence of reliance upon the contents of this eCoC.

# ELECTRICAL CERTIFICATE OF COMPLIANCE

As required by the *Electricity Act 1996*

Certificate Number: **E1589586**

## **Information for Owners and Operators of Electrical Installations**

(From the *Electricity Act 1996*)

### **Section 60 of the *Electricity Act 1996***

#### **60—Responsibility of owner or operator of infrastructure or installation**

(1b) A person who owns or operates an electrical installation must take reasonable steps to ensure that—

- (a) the installation complies with, and is operated in accordance with, technical and safety requirements imposed under the regulations; and
- (b) the installation is safe and safely operated.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.

(2) For the purpose of ensuring under this section that an electrical installation complies with the technical and safety requirements and is safe, a person may, subject to the regulations, rely on a certificate of compliance issued under this Part in relation to the installation.

### **Section 61 of the *Electricity Act 1996***

#### **61—Electrical installation work**

(1) A person to whom this subsection applies who carries out work on an electrical installation or proposed electrical installation must ensure that—

- (a) the work is carried out as required under the regulations; and
- (b) examinations and tests are carried out as required under the regulations; and
- (c) the requirements of the regulations as to notification and certificates of compliance are complied with.

Maximum penalty:

- (a) if the offender is a body corporate—a penalty of \$50 000;
- (b) in any other case—a penalty of \$10 000.

Expiation fee: \$315.