



DYNAMIC EXPORTS GUIDELINES

Compliance Timeline

From 1 July 2023

Small Embedded Generator (SEG) Connections (< 30 kW)

All new installations intending to export to the grid must use certified dynamic export-capable equipment from CEC or transitional listings (detailed in guideline sections 9.8.2 & 10.5.2).

Sites using a *dynamic export capable connection agreement* must also pass the *dynamic exports capability test* as part of installation commissioning.

Sites with no option to connect via a *dynamic export capable connection agreement* may have reduced compliance requirements (as described in guideline sections 9.8.3 and 10.5.3).

SEG Exceptions & Exemptions

For sites which applied for a connection agreement prior to **1 July 2023**, compliance with the dynamic exports guidelines is not required if that site's installation is completed prior to **1 September 2023**.

Sites using a static export connection are not required to complete the dynamic exports capability test as part of commissioning.

Sites configured to permanent zero export are exempt from dynamic export compliance requirements.

Other Exceptions & Exemptions

Battery systems installed without Solar PV generation are exempt until **1 March 2024**. (See section 8.3.2 for more information).

Medium embedded generators (MEG) with generator capacity >30kW - 200kW are exempt from dynamic export compliance requirements until **1 July 2024**.

Battery System Exemption Ends

Battery energy storage system exemption is removed. All new battery installations installed after **1 March 2024** must use dynamic export capable equipment and pass the *dynamic export capability test* as part of commissioning.

(See guideline sections 9.7.2 & 10.4.2 for detail)

Transitional Listing Arrangement Ends

Transitional exemption listings of compliant *electricity generating plant* are removed. All new export-capable sites installed after **1 April 2024** must use dynamic export capable equipment as listed by the CEC and pass the *dynamic export capability test* as part of commissioning.

(See guideline sections 9.8.2 & 10.5.2 for further details)

Medium Embedded Generator (>30kW - 200kW) Exemption Ends

Dynamic export compliance exemption for MEG plant ends. From 1 July 2024 dynamic export compliance is mandatory for all new MEG installations. New MEG installations must also pass the *dynamic export capability test* during commissioning to achieve compliance.

From 1 March 2024

From 1 April 2024

From 1 July 2024

Click here to view the [Technical Regulator Guidelines](#)

energymining.sa.gov.au/dynamicexports



Government of South Australia
Department for Energy and Mining